
DFIG AGENDA

2-25-2015

Weekly Recap

- Design Review Recap and Debrief
- RSCAD model
 - Doesn't want to sync to the grid
 - Worked with Dr. Johnson and Alaap on model
 - When disconnected from grid DFIG outputs 8kV (suppose to be 690V)
 - Found that constants in D&Q calculations might be the reason
- **CONTROLS UPDATE**
 - Got some code generated

Need to do

- E-mail Normann about RSCAD Model (ask if he wants our model at 690V or 208V as the power grid is 208V)
- Finish Expo documents
- What additional material do we need to send to Dr. Li for 591 presentation
- Need to create ppt for 591 presentation.